



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-168-14**

Valid from: 2022 07 25
until: 2023 07 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Appliance inlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3694-1854/22**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2022 07 26



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
IEC 60309-1:2021
IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Appliance inlets for industrial purposes

Type designation:

Rating:

Trademark:

543

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

643

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

743

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

544

Rated current: 125 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

644

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

744

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

545

Rated current: 125 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

645

Rated current: 125 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

745

Rated current: 125 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

5432

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6432

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7432

Rated current: 125 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

5442

Rated current: 125 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6442

Rated current: 125 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7442

Rated current: 125 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

5452

Rated current: 125 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

6452

Rated current: 125 A

Insulation voltage: 690 V

3P+N+PE

IP 67 or IP 66/IP 67

without pilot contact, appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7452

Rated current: 125 A

Insulation voltage: 690 V

3P+N+PE

IP 67 or IP 66/IP 67

without pilot contact, appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz
543 5432 643 6432 743 7432	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
544 5442 644 6442 744 7442	125	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380 440	50 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
		12	Supply from an isolating transformer	50 and 60
		545 5452 645 6452 745 7452	125	1
2	>50			>300 - 500
3	220/380 250/440			50 60
4	57/100 – 75/130			50 and 60
5	347/600 – 400/690			50 and 60
6	200/346 – 240/415			50 and 60
7	277/480 – 288/500			50 and 60
9	120/208 – 144/250			50 and 60
10	>50			>100 - 300
11	250/440 – 265/460			60
12	Supply from an isolating transformer			50 and 60

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

Typecode

5	4	5	2	-	6	*	*
---	---	---	---	---	---	---	---

Contacts	
blank	Nickel plated contacts
b	uncoated contacts
Colour	
blank	Standard type
*	Reserved for additional colours
Clock position earthing contact	
1	1h
2	2h
3	3h
4	4h
5	5h
6	6h
7	7h
8	8h
9	9h
10	10h
11	11h
12	12h
Customer type	
-	PCE
Pilot contact	
2	without pilot contact
blank	with pilot contact
Poles	
3	3-poles
4	4-poles
5	5-poles
Rated current	
4	125 A
Ground type	
5	Wall mounted appliance-inlet
6	Appliance-inlet straight
7	Appliance-inlet sloping

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

ts1252 •

Colour

- g - grey
- * - reserved for additional colours

Accessory

ts1252 Water protection cap IP67 or IP66/IP67

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.