2-conductor lighting connector; push-button on lighting side; Lighting side: for all conductor types; Inst. side: for solid conductors; 224 Series; max. 2.5 mm²; Surrounding air temperature: max 60°C; 2,50 mm²; white




https://www.wago.com/224-112





Color: white



Dimensions in mm

٠.		
N	nt	es

Safety information in grounded power lines

#### Electrical data

Ratings per IEC/EN	
Ratings per	EN 60664
Nominal voltage (II/2)	400 V
Rated surge voltage (II/2)	4 kV
Rated current	24 A
Legend (ratings)	(II / 2) ≙ Overvoltage category II / Pollution degree 2

#### Connection data

# Data Sheet | Item Number: 224-112 https://www.wago.com/224-112





Connection 1	
Connection type 1	Installation side
Connection technology	PUSH WIRE®
Number of connection points	2
Actuation type	Push-in
Connectable conductor materials	Copper Aluminum
Connectable conductor materials (note)	Terminating Aluminum Conductors WAGO spring clamp terminal blocks are suitable for solid aluminum conductors up to 4 mm²/12 AWG if WAGO "Alu-Plus" Contact Paste <a href="https://www.wago.com/249-130">249-130</a> is used for termination.
	"Alu-Plus" Contact Paste Advantages:
	<ul> <li>Automatically destroys the oxide film during clamping.</li> <li>Prevents fresh oxidation at the clamping point.</li> <li>Prevents electrolytic corrosion between aluminum and copper conductors (in the same terminal block).</li> <li>Provides long-term protection against corrosion.</li> </ul>
	Using terminal blocks with CAGE CLAMP® Spring Pressure Connection Technology, aluminum conductors must first be cleaned with a blade and then immediately be inserted into the clamping units filled with "Alu-Plus" Contact Paste.
	For spring clamp connections with PUSH WIRE® connection technology, <b>WAGO</b> recommends that the aluminum conductor first be cleaned and then immediately inserted into the clamping unit filled with "Alu-Plus" contact paste.
	It is also possible to apply WAGO "Alu- Plus" <b>additionally</b> on the whole surface of the aluminum conductor before termi- nation.
	Please note that the nominal currents must be adapted to the reduced conductivity of the aluminum conductors:: 2.5 mm² = 16 A 4 mm² = 22 A
Solid conductor	1 2.5 mm² / 16 14 AWG
Strip length	9 11 mm / 0.35 0.43 inches
Wiring direction	Side-entry wiring

Connection 2	
Connection type 2	Lighting side
Connection technology 2	CAGE CLAMP®
Number of connection points 2	1
Solid conductor 2	0.5 2.5 mm² / 20 14 AWG
Fine-stranded conductor 2	0.5 2.5 mm <sup>2</sup> / 20 16 AWG

https://www.wago.com/224-112



#### Physical data Width 9.5 mm / 0.374 inches Height 15.5 mm / 0.61 inches Depth 20.5 mm / 0.807 inches

Material data	
Note (material data)	Information on material specifications can be found here
Color	white
Fire load	0.047 MJ
Weight	2.1 g

Environmental requirements	
Ambient temperature (operation)	+60 °C
Continuous operating temperature	105 °C

Commercial data	
Product Group	7 (Push Wire Conn.)
eCl@ss 10.0	27-14-11-03
eCl@ss 9.0	27-14-11-03
ETIM 8.0	EC000447
ETIM 7.0	EC000447
PU (SPU)	1000 (100) pcs
Packaging type	Вох
Country of origin	СН
GTIN	4044918583596
Customs tariff number	85369010000

Environmental Product Compliance	
RoHS Compliance Status	Compliant,No Exemption

## Approvals / Certificates

# General approvals



rungsinstitut









WIRE CONNECTOR 667F		
Approval	Standard	Certificate Name
CSA DEKRA Certification B.V.	C22.2	1053495
UL UL International Germany GmbH	UL 486C	E69654
UL UL International Germany GmbH	EN 60998	CCA-2617-A1
UL UL International Germany GmbH	EN 60998	D-05895-A1 (EN60998-1 EN60998-2-2)
VDE VDE Prüf- und Zertifizie-	EN 60998	40022792

# Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Conformity WAGO GmbH & Co. KG	-	-

https://www.wago.com/224-112



## Approvals for marine applications










- INVECTOR(NO	
Standard	Certificate Name
-	18-HG1755093-PDA
EN 60998	11914/D0 BV
EN 60998	TAE000015T
EN 60998	LR22207029TA
	Standard - EN 60998 EN 60998

# Downloads Environmental Product Compliance Compliance Search Environmental Product Compliance 224-112

Documentation			
Bid Text			
224-112	19.02.2019	xml 3.46 KB	<u>↓</u>
224-112	21.02.2019	docx 15.55 KB	$\downarrow$



1 Compatible Products	
1.1 Optional Accessories	
1.1.1 Tool	

https://www.wago.com/224-112



#### 1.1.1.1 "Alu-Plus" contact paste



<u>Item No.: 249-130</u>


Syringe; Contents: 20 ml Alu-Plus contact paste

#### **Installation Notes**

#### Conductor termination







Strip conductor to 9  $\dots$  11 mm (0.35  $\dots$  0.43 inch).

#### Conductor termination





To connect: Press button fully, insert stripped conductor into square entry and release.



To remove: Press button and withdraw conductor.

#### **Conductor termination**





To connect: Insert stripped solid conductor into circular entry and push until it hits the backstop.



To remove: Hold conductor to be removed and twist alternately left and right while slightly pulling the connector.

#### Testing



Testing via separate test ports.

Subject to changes. Please also observe the further product documentation!

Current addresses can be found at::  $\underline{www.wago.com}$ 

Page 5/5 Version 02.05.2023