

## CERTIFICATE FI/40605/A1

Our Ref. HEL-CERT200300107-02



**Product** Branch joint

**Type** KF 7.70  
KF 8.70

**Trademark** ENSTO and/or

**Certificate Holder** Ensto Building Systems Finland Oy  
Ensio Miettisen katu 2, FI-06150, Porvoo, Finland

**Technical information** Cu 6 – 70 mm<sup>2</sup>, Un 750 V

**Other information** See page 2

**The product is certified according to the following standard(s)** EN 60947-7-1:2009


**Validity** This certificate is valid until 2025-03-11 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

**Date of issue** 2021-04-30

**SGS Fimko Ltd**

**Signature**

Joonas Leinonen  
Certification Manager



**Manufacturer** Ensto Building Systems Finland Oy  
Enso Miettisen katu 2, FI-06150, Porvoo, Finland

**Manufacturing site** Ensto Building Systems OÜ  
Keki 1, EE-76606, Keila, Estonia

**Directive information** The certified product(s) fulfils requirements of mentioned standard(s) which are harmonised under the Low Voltage Directive (2014/35/EU) at the date of issue of the certificate.

**Additional information** Method of fixing:  
mounting rail IEC 715/TH35-7,5 (TS35) or screw-mounting

Ability to receive Cu conductors  
7 x 6 mm<sup>2</sup> - 10 mm<sup>2</sup>  
6 x 16 mm<sup>2</sup>  
4 x 25 mm<sup>2</sup> - 35 mm<sup>2</sup>  
2 x 50 mm<sup>2</sup> - 70 mm<sup>2</sup>  
1 x 95 mm<sup>2</sup>

KF 7.70 4-pole branch joint  
KF 8.70 1-pole branch joint

This certificate replace previous certificate FI/40605, dated 2020-03-11, due to name change of certificate holder, manufacturer and factory.

**As shown in the Test Report(s) No(s):** 299067-1