

# ATTESTATION OF CONFORMITY

Issued to: NOARK Electrics (Shanghai) Co., Ltd.  
Block V-7A-1, Songjiang Industrial Zone, Shanghai, P. R. China

For the product: Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO)

Trade name: NOARK

Type/Model: Ex9BL-N, Ex9BL-H

Ratings: 1P+N, Ue = 220 / 230 / 240 Vac, 50 Hz  
In = 6, 10, 13, 16, 20, 25, 32, 40 A, B and C type  
IΔn = 30, 100, 300 mA, type A and AC, without time-delay  
Ex9BL-N: Ics = Icn = 6000 A  
Ex9BL-H: Ics = 7500 A, Icn = 10000 A,  
IΔm = 3000 A  
Energy limiting class 3

Manufactured by: Zhejiang Chint Electrics Co., Ltd.  
No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing,  
Zhejiang, P. R. China

Subject: Type Test

Remark: This Attestation is based on AoC No. 3306513.01A issued on 2014-06-16.

Requirements: EN 61009-1:2012; EN 61009-2-1:1994 + A11:1998,  
IEC 61009-1:2010 + A1:2012, IEC 61009-2-1:1991

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no W0811042.50, 3302588.50, 3302588.51, 3302588.52, 3302588.53, 3306513.50, 3306652.50 and 3307148.50.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2006/95/EC.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 17 November 2014

Number: 3307148.01A

  
F.S. Strikwerda  
Certification Manager

DEKRA Certification B.V.

© Integral publication of this attestation and adjoining reports is allowed

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.



DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands  
T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396