



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-214-07**

Valid from: 2024 02 17  
until: 2026 02 17

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Certificate holder: **PC Electric Ges.m.b.H.**  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

Product: **Switched socket-outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the certificate holder holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **3704-1856/22**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=[t.neumayer@ove.at](mailto:t.neumayer@ove.at)

Dipl.-Ing. T. Neumayer



Wien, 2024 01 08

## OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



**Manufacturer:**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Factory location(s):**

PC Electric Ges.m.b.H.  
Diesseits 145  
4973 St. Martin im Innkreis  
Austria

**Tested and certified according to:**

ÖVE/ÖNORM EN 60309-1:2013-03-01  
ÖVE/ÖNORM EN 60309-2:2013-03-01  
ÖVE/ÖNORM EN 60309-4:2012-12-01  
OVE EN IEC 60309-1:2023-07-01  
OVE EN IEC 60309-2:2023-07-01  
OVE EN IEC 60309-4:2023-04-01  
IEC 60309-1:2021  
IEC 60309-2:2021  
IEC 60309-4:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Switched socket-outlets for industrial purposes**

**Type designation:**

**Rating:**

**Trademark:**

**7523**

Rated current: 32 A  
2P+E  
IP44 or IP44/IP54  
Screw terminals  
with switch  
see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**7623**

Rated current: 32 A  
2P+E  
IP44 or IP44/IP54  
Screw terminals  
with switch and DIN-rail  
see typelist

PCE / ELCEE / SIROX / METECEE

**7823**

Rated current: 32 A  
2P+E  
IP44 or IP44/IP54  
Screw terminals  
with switch and fuse  
see typelist

PCE / ELCEE / SIROX / METECEE

**75232**

Rated current: 32 A  
2P+E  
IP67 or IP66/IP67  
Screw terminals  
with switch  
see typelist

PCE / ELCEE / SIROX / METECEE

**76232**

Rated current: 32 A  
2P+E  
IP67 or IP66/IP67  
Screw terminals  
with switch and DIN-rail  
see typelist

PCE / ELCEE / SIROX / METECEE

**78232**

Rated current: 32 A  
2P+E  
IP67 or IP66/IP67  
Screw terminals  
with switch and fuse  
see typelist

PCE / ELCEE / SIROX / METECEE

**7524**

Rated current: 32 A  
3P+E  
IP44 or IP44/IP54  
Screw terminals  
with switch  
see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**7624**

Rated current: 32 A  
3P+E  
IP44 or IP44/IP54  
Screw terminals  
with switch and DIN-rail  
see typelist

PCE / ELCEE / SIROX / METECEE

**7824**

Rated current: 32 A  
3P+E  
IP44 or IP44/IP54  
Screw terminals  
with switch and fuse  
see typelist

PCE / ELCEE / SIROX / METECEE

**75242**

Rated current: 32 A  
3P+E  
IP67 or IP66/IP67  
Screw terminals  
with switch  
see typelist

PCE / ELCEE / SIROX / METECEE

**76242**

Rated current: 32 A  
3P+E  
IP67 or IP66/IP67  
Screw terminals  
with switch and DIN-rail  
see typelist

PCE / ELCEE / SIROX / METECEE

**78242**

Rated current: 32 A  
3P+E  
IP67 or IP66/IP67  
Screw terminals  
with switch and fuse  
see typelist

PCE / ELCEE / SIROX / METECEE

**7525**

Rated current: 32 A  
3P+N+E  
IP44 or IP44/IP54  
Screw terminals  
with switch  
see typelist

PCE / ELCEE / SIROX / METECEE

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

**7625**

Rated current: 32 A  
3P+N+E  
IP44 or IP44/IP54  
Screw terminals  
with switch and DIN-rail  
see typelist

PCE / ELCEE / SIROX / METECEE

**7825**

Rated current: 32 A  
3P+N+E  
IP44 or IP44/IP54  
Screw terminals  
with switch and fuse  
see typelist

PCE / ELCEE / SIROX / METECEE

**75252**

Rated current: 32 A  
3P+N+E  
IP67 or IP66/IP67  
Screw terminals  
with switch  
see typelist

PCE / ELCEE / SIROX / METECEE

**76252**

Rated current: 32 A  
3P+N+E  
IP67 or IP66/IP67  
Screw terminals  
with switch and DIN-rail  
see typelist

PCE / ELCEE / SIROX / METECEE

**78252**

Rated current: 32 A  
3P+N+E  
IP67 or IP66/IP67  
Screw terminals  
with switch and fuse  
see typelist

PCE / ELCEE / SIROX / METECEE

---

**OVE Certification**

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

### Type code

75	2	3	2	-	6	*	*	*
----	---	---	---	---	---	---	---	---

#### Switch

blank	ML0 (4-poles 3h only available with ML1)
ml1	ML1

#### Contacts

blank	Nickel plated contacts
b	Uncoated contacts

#### Colour

blank	Indicating colour
xs	Midnight-series
*	Reserved for additional colours

#### Clock position earthing contact

1	1 h
3	3 h (not available for series 78)
4	4 h
5	5 h (not available for series 78)
6	6 h
7	7 h (not available for series 78)
9	9 h
11	11 h (not available for series 78)
12	12 h

#### Customer type

-	Trademark PCE
---	---------------

#### Degree of protection

blank	IP44 or IP44/IP54
2	IP67 or IP66/IP67

#### Poles

3	3-poles
4	4-poles
5	5-poles

#### Rated current

2	32 A
---	------

#### Ground type

75	With switch
76	With switch and DIN-rail
78	With switch and fuse (Neozed)

### OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

## Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz	Insulation voltage V
<b>7523 7623 7823*) 75232 76232 78232*)</b>	32	1	Other ratings	Other ratings	690 / 415*)
		4	100 – 130	50 and 60	690 / 415*)
		6	200 – 250	50 and 60	690 / 415*)
		9	380 – 415	50 and 60	690 / 415*)
		12	Supply from an isolating transformer	50 and 60	690 / 415*)
<b>7524 7624 7824*) 75242 76242 78242*)</b>	32	1	Other ratings	Other ratings	690 / 415*)
		3**)	380 440	50 60	690
		4	100 – 130	50 and 60	690 / 415*)
		5	600 – 690	50 and 60	690
		6	380 – 415	50 and 60	690 / 415*)
		7	480 - 500	50 and 60	690
		9	200 – 250	50 and 60	690 / 415*)
		11	440 – 460	60	690
		12	Supply from an isolating transformer	50 and 60	690 / 415*)
<b>7525 7625 7825*) 75252 76252 78252*)</b>	32	1	Other ratings	Other ratings	690 / 415*)
		3	220/380 250/440	50 60	690
		4	57/100 – 75/130	50 and 60	690 / 415*)
		5	347/600 – 400/690	50 and 60	690
		6	200/346 – 240/415	50 and 60	690 / 415*)
		7	277/480 – 288/500	50 and 60	690
		9	120/208 – 144/250	50 and 60	690 / 415*)
		11	250/440 – 265/460	60	690
		12	Supply from an isolating transformer	50 and 60	690 / 415*)

\*) Insulating voltage 415 V for Series 78... with fuses (Neozed)

\*\*) Only available with switch ML1

### OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.