

Cooper Lighting and Safety Ltd.
Wheadoy Half Flood.
Dennestor
South Yorkshire, DAZ 4188
United Kayptom
Telephone +44 (0) 1302 321541
Email: Info@copper-h.co.uk

CE DECLARATION OF CONFORMITY

Date: 16/04/2014

We: Cooper Lighting and Safety Ltd.

Of: Wheatley Hall Road, Doncaster, South Yorkshire, DN2 4NB

In accordance with the following directives:

- 2006/95/EC Low Voltage Directive (LVD)
- 2004-108/EC Electromagnetic Compatibility (EMC)
- 2011/65/EU Restriction of the use of certain hazardous substances (RoHS)

Declare that the product range: Halo-Pack 2

Description: High performance LED self-contained emergency luminaire with 3W LED.

Is manufactured in accordance with the sections of the following standards (where applicable):

✓ BS EN 60598-1 Luminaires General Requirements and Test

✓ BE EN 61000-4-3 Electromagnetic Compatibility

✓ BS EN 55015 Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment

✓ BS EN 61547 EMC, Immunity Requirements

✓ BS EN 60598-2-22 Luminaires, particular requirements, luminaires for emergency lighting

We hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced standards and applicable essential requirements of the named directives.

This assumes a Residential, Commercial and Light Industrial EMC environment. Where a different environment is expected or required please contact Cooper Lighting and Security Itd for advice and where appropriate a product specific declaration.



Position at Company: Head of Quality