



## **DECLARATION OF CONFORMITY**



Manufacturer:

PRYSMIAN FINLAND OY

Reg No:

D015015 Rev A

Address:

P.O.Box 13

FI-02401 Kirkkonummi

**Factory:** 

Oulu

hereby declare that the cable

Type:

FIRETUF FRHF

Fire resistant installation cable

Rated voltage:

300/500 V ja 450/750 V

Number of conductors:

2-19

Conductor cross-section:

1,5 - 10

 $mm^2$ 

has been designed and manufactured in accordance with the following standards

 EN 50200
 2006

 EN 50362
 2003

 EN 60332-3-23
 2009

 IEC 60502-1
 2004

 IEC 60227-4
 1997

Number and dates of issue

and conforms to the relevant safety provisions of the Directive (2006/95/EY). The product complies in addition to the provisions of the following Directive(s)

**EU RoHS Directive** 

2011/65/EU

Name and number of the directive(s)

References to measures taken to ensure the conformity of the product with the provisions of the Directive(s)

**Test Report** 

Certificates, test reports, issuer, number

It is ensured through internal measures and quality control that products conform all times to the requirements of the current Directive(s) and the relevant standards.

Pikkala, 16 June, 2014

Place and date of issue

Jussi Mäki (Manager, Qualit

Name and position of signatory

Signature