

DECLARATION OF CONFORMITY

Manufacturer: **PRYSMIAN FINLAND OY**Reg No: **D015015**
Rev AAddress: **P.O.Box 13**
FI-02401 KirkkonummiFactory: **Oulu**

hereby declare that the cable

Type:	FIRETUF FRHF	Fire resistant installation cable
Rated voltage:	300/500 V ja 450/750 V	
Number of conductors:	2-19	
Conductor cross-section:	1,5 - 10	mm²

has been designed and manufactured in accordance with the following standards

EN 50200	2006
EN 50362	2003
EN 60332-3-23	2009
IEC 60502-1	2004
IEC 60227-4	1997

Number and dates of issue


and conforms to the relevant safety provisions of the Directive (2006/95/EY).
The product complies in addition to the provisions of the following Directive(s)

EU RoHS Directive	2011/65/EU
--------------------------	-------------------

Name and number of the directive(s)

References to measures taken to ensure the conformity of the product with
the provisions of the Directive(s)**Test Report**

Certificates, test reports, issuer, number

It is ensured through internal measures and quality control that products conform
all times to the requirements of the current Directive(s) and the relevant standards.**Pikkala, 16 June, 2014**
Place and date of issue**Jussi Mäki (Manager, Quality)**
Name and position of signatory
Signature