


<b>DECLARATION OF CONFORMITY</b>	No. 09QD-16ENG/V4	Date 11.05.2016	<b>CE</b> 12
Product DISTRIBUTION CABLES OF RATED VOLTAGE $U_0 / U = 0.6 / 1$ kV Type AXMK-PLUS (AXPK-PLUS / SE-N1XE-AS PLUS F2) 0,6 / 1 kV			
Manufacturer Draka Keila Cables Ltd, Paldiski road 31, Keila 76606 Estonia			
Manufactured according to: EVS-HD 603 S1 Part 5 Section D IEC 60502-1 SFS 4879			
Fire resistance according to IEC 60332-1-2 and EN 60332-1-2			
The goods have been inspected and tested in accordance with the abovementioned technical specifications and they were found to meet all requirements stated.  Cable is CE marked and meet the requirement of Low Voltage Directive 2014/35/EU.  All used plastic materials are UV resistable and they don't need extra protection against sunlight.			
The management system of the company has found to be in conformance to ISO 9001 and ISO 14001 and OHSAS 18001 standards			
Company follows and complies with the requirements of the European Commission Regulation No. 1907/2006 (REACH), likewise we will claim this from our corresponding sub suppliers.			

**Draka Keila Cables**  
**Quality Department**



**Helle Oranen**  
**Quality Manager**



Note: HD 603 S1- this Harmonization Document was approved by CENELEC on 1993 - 12 - 08. CENELEC members are bound to comply with the CEN / CENELEC Internal Regulations which stipulate the conditions for implementation of this Harmonization Document on a national level.

