

Order No. 383614

CERTIFICATE No. P14218468/A1

PAGE 1 of 3

Product	Thermostat
Applicant	Danfoss A/S Nordborgvej 81 DK 6430 Nordborg Denmark
Manufacturer	Danfoss A/S Nordborgvej 81 DK 6430 Nordborg Denmark
Factory	Escatec Electronics Sdn. Bhd. Plot 107, Jalan Hilir Sungai Keluang 5, Bayan Lepas Industrial Park, Phase 4, Bayan Lepas, Pulau Penang 11900 Malaysia
Ratings	16A 220-240V AC 50Hz
Trade mark	DEVI
Model / Type Ref.	DEVIreg 330
Principal characteristics	Thermostat for DIN-rail mounting, type 1.B action, micro-disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T50, (-10 - +10°C), IP20
A sample of the product was tested and found to be in conformity with	CONT EN 60730-1:2011 EN 60730-2-9:2010
Replaces	This certificate replaces previous certificate No. P14218468, due to change address in applicant/manufacturer and factory and change model name from EFET 330 to ECtemp 330.
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	
Additional model(s)	(5) See page 2

Date of issue 26-09-2019

)iyea Gīm

Jiyea Gim Certification Department

Nemko AS Philip Pedersens vei 11, 1366 Lysaker, Norway TEL +47 22 96 03 30 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532



Order No. 383614

CERTIFICATE

No. P14218468/A1



Additional model(s)	
Product Pos. No Model / Type Ref. Trade mark (if different from page 1) Rating	Thermostat 1 DEVIreg 330 16A 220-240V AC 50Hz
Principal characteristics	Thermostat for DIN-rail mounting, type 1.B action, micro-disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T50, (-5 - +45°C), IP20
Product Pos. No	Thermostat 2
Model / Type Ref. Trade mark (if different from page 1)	DEVIreg 330
Rating Principal characteristics	16A 220-240V AC 50Hz Thermostat for DIN-rail mounting, type 1.B action, micro-disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T50, (-60 - +160°C), IP20
Product Pos. No Model / Type Ref. Trade mark (if different from page 1) Rating Principal characteristics	Thermostat 3 ECtemp 330 Danfoss 16A 220-240V AC 50Hz Thermostat for DIN-rail mounting, type 1.B action, micro-disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T50, (-10 - +10°C), IP20
Product Pos. No Model / Type Ref. Trade mark (if different from page 1) Rating Principal characteristics	Thermostat 4 ECtemp 330 Danfoss 16A 220-240V AC 50Hz Thermostat for DIN-rail mounting, type 1.B action, micro-disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T50, (-5 - +45°C), IP20

Date of issue 26-09-2019

liyea ร์โท

Jiyea Gim Certification Department

Nemko AS Philip Pedersens vei 11, 1366 Lysaker, Norway TEL +47 22 96 03 30 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532



CERTIFICATE

No. P14218468/A1



Product Pos. No Model / Type Ref. Trade mark (if different from page 1) Rating Principal characteristics

Thermostat

5 ECtemp 330 Danfoss 16A 220-240V AC 50Hz Thermostat for DIN-rail mounting, type 1.B action, micro-disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T50, (-60 - +160°C), IP20

Date of issue 26-09-2019

Jiyea Gim Certification Department

Nemko AS Philip Pedersens vei 11, 1366 Lysaker, Norway TEL +47 22 96 03 30 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532