

Order No. 383613

CERTIFICATE No. P14218464/A1



Product	Thermostat
Applicant	Danfoss A/S Nordborgvej 81 DK 6430 Nordborg Denmark
Manufacturer	Danfoss A/S Nordborgvej 81 DK 6430 Nordborg Denmark
Factory	Escatec Electronics Sdn. Bhd. Plot 107, Jalan Hilir Sungai Keluang 5, Bayan Lepas Industrial Park, Phase 4, Bayan Lepas, Pulau Penang 11900 Malaysia
Ratings	10A 220-240V AC 50Hz
Trade mark	DEVI, Danfoss
Model / Type Ref.	D528
Principal characteristics	DEVI = DEVIreg 528 and Danfoss = ECtemp 528. Independently mounted thermostat for flush mounting. Type 1B action, micro- disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T30, IP31
A sample of the product was tested and found to be in conformity with	CONT EN 60730-1:2011 EN 60730-2-9:2010
Replaces	This certificate replaces previous certificate No. P14218464, due to update address in applicant, manufacture, factory and removal of one model.
Validity	This certificate documents conformity with the standards shown, and also applies as license for use of Nemkos name and certification mark. The certificate and license is valid as long as the applicable conditions are complied with, and provided that any changes to the product are notified to Nemko for acceptance prior to implementation. New standards or amendments to the standards may imply that the product design must be updated and/or that re-testing and re-certification is necessary.
Additional information	
Additional model(s)	(4) See page 2

Date of issue 26-09-2019

)iyea Gīm

Jiyea Gim Certification Department

Nemko AS Philip Pedersens vei 11, 1366 Lysaker, Norway TEL +47 22 96 03 30 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532



Order No. 383613

CERTIFICATE

No. P14218464/A1



Additional model(s)	
Product Pos. No Model / Type Ref. Trade mark (if different from page 1) Rating Principal characteristics	Thermostat 1 D530
	15A 220-240V AC 50Hz DEVI = DEVIreg 530 and Danfoss = ECtemp 530. Independently mounted thermostat for flush mounting. Type 1B action, micro- disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T30, IP31
Product Pos. No Model / Type Ref. Trade mark (if different from page 1) Rating Principal characteristics	Thermostat 2 D530M
	15A 220-240V AC 50Hz DEVI = DEVIreg 530M and Danfoss = ECtemp 530M. Independently mounted thermostat for flush mounting. Type 1B action, micro- disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T30, IP31
Product Pos. No	Thermostat 3
Model / Type Ref. Trade mark (if different from page 1)	D531
Rating Principal characteristics	15A 220-240V AC 50Hz DEVI = DEVIreg 531 and Danfoss = ECtemp 531. Independently mounted thermostat for flush mounting. Type 1B action, micro- disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T30, IP31
Product Pos. No	Thermostat 4
Model / Type Ref. Trade mark (if different from page 1) Rating Principal characteristics	D532
	15A 220-240V AC 50Hz DEVI = DEVIreg 532 and Danfoss = ECtemp 532. Independently mounted thermostat for flush mounting. Type 1B action, micro- disconnection, overvoltage category III, pollution degree II, category D, PTI 175, Class II, with pillar terminals, -10T30, IP31

Date of issue 26-09-2019

liyea รโท

Jiyea Gim Certification Department

Nemko AS Philip Pedersens vei 11, 1366 Lysaker, Norway TEL +47 22 96 03 30 EMAIL info@nemko.com ENTERPRISE NUMBER NO974404532