OVE Austrian Electrotechnical Association

Eschenbachgasse 9 | 1010 Wien | Austria

ZVR: 327279890 | www.ove.at

OVE Certification

Kahlenberger Str. 2A | 1190 Wien | Austria T +43 1 370 58 06 | certification@ove.at

Validity of ÖVE-Certificates can be checked at www.ove.at



Page 1 of 6

ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: 43-153-14 Valid from: 2023 01 12

until: 2025 01 12

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

PC Electric Ges.m.b.H. Company:

Diesseits 145

4973 St. Martin im Innkreis

Austria

Product: Plug for industrial purposes

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s):: 3694-1851/22

Österreichischer Verband für Elektrotechnik

Head of OVE Certification


Digitally signed by T. Neumayer Email=t neumayer@ove.at Digitally signed by T. Neumayer

Dipl.-Ing. T. Neumayer



Wien, 2023 01 12









Date: 2023 01 12 Page 2 of 6

Manufacturer:

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Factory location(s):

PC Electric Ges.m.b.H. Diesseits 145 4973 St. Martin im Innkreis Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01 ÖVE/ÖNORM EN 60309-2:2013-03-01 EN IEC 60309-1:2022 EN IEC 60309-2:2022 IEC 60309-1:2021 IEC 60309-2:2021

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Plug for industrial purposes

Type designation: Rating:	Trademark:
043 2P+PE IP 67 or IP 66/IP 67 Rated insulation voltage: 690 V with pilot contact see typelist	PCE / ELCEE / SIROX / METECEE
044	PCE / ELCEE / SIROX / METECEE

3P+PE IP 67 or IP 66/IP 67 Rated insulation voltage: 690 V with pilot contact

with pilot contact see typelist

OVE Certification Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products

within the scope as given in the official decree and published under https://akkreditierung-austria.gv.at.





Date: 2023 01 12

Page 3 of 6

045 PCE / ELCEE / SIROX / METECEE

3P+N+PE
IP 67 or IP 66/IP 67
Rated insulation voltage: 690 V
with pilot contact
see typelist

0432 PCE / ELCEE / SIROX / METECEE

2P+PE IP 67 or IP 66/IP 67 Rated insulation voltage: 690 V without pilot contact see typelist

0442 PCE / ELCEE / SIROX / METECEE

3P+PE
IP 67 or IP 66/IP 67
Rated insulation voltage: 690 V
without pilot contact
see typelist

0452 PCE / ELCEE / SIROX / METECEE

IP 67 or IP 66/IP 67 Rated insulation voltage: 690 V without pilot contact see typelist

3P+N+PE



Date: 2023 01 12 Page 4 of 6

Typelist

Туре	Rated current A	Earthing contact pos.	Rated operating voltage V	Frequency Hz
		1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
043 0432		6	200 – 250	50 and 60
	125	7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
		1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380	50
Í			440	60
		4	100 – 130	50 and 60
044		5	600 – 690	50 and 60
0442	125	6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
		12	Supply from an isolating transformer	50 and 60
		1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	220/380 250/440	50 60
		4	57/100 – 75/130	50 and 60
045		5	347/600 - 400/690	50 and 60
0452	125	6	200/346 – 240/415	50 and 60
		7	277/480 – 288/500	50 and 60
		9	120/208 – 144/250	50 and 60
		10	>50	>100 - 300
		11	250/440 – 265/460	60
		12	Supply from an isolating transformer	50 and 60





Date: 2023 01 12 Page 5 of 6

Typecode

_	_				1	1	_		Π.	. 1		1	ıy	pecode
0	4	5)	2	-		6	cq	,	•	*			
													Contacts	S
													blank	Nickel plated contacts
												•	b	uncoated contacts
												•	Colour	
													blank	Standard type
												Ī	*	Reserved for additional colours
													Housing	
													blank	Design 1
													cq	Design 2
													Clock po	osition earthing contact
													1	1h
													2	2h
													3	3h
													4	4h
													5	5h
													6	6h
													7	7h
												L	8	8h
													9	9h
													10	10h
													11	11h
													12	12h
													Custome	
													-	PCE
													Pilot cor	
												-	2	without pilot contact
													blank	with pilot contact
		L											Poles	
													3	3-poles
													4	4-poles
													5	5-poles
													Rated cu	
													4	125 A
													Ground	
													0	Plug

OVE Certification





Date: 2023 01 12 Page 6 of 6

ts1252 •

Colour

g - grey
* - rese

reserved for additional colours

Accessory

ts1252 Water protection cap IP67 or IP66/IP67



